

## **Homewood Fire Marshal's Office requirements for a New Business License inspection:**

1. Proper address on the front of the building
2. Knox Box mounted to the front of the building, approximately 54 inches high. Knoxbox.com 3200 series use Homewood Alabama for the code.
3. Code compliant door hardware, example no locks that you have to pinch or grab to open the door. Example of a code compliant hardware is a dead latch paddle.
4. Ten pound ABC fire extinguisher with a third party inspection tag within 75 feet travel distance anywhere in the building.
5. Exit and egress lighting marking the path of egress out of the building.
6. Electrical panel that has the breakers labeled and no missing open spaces in the breaker box.
7. If the building is equipped with a sprinkler system have an up to date inspection tag.
8. If the building is equipped with a fire alarm system have an up to date inspection and system must show normal.